


**Nota :**  
Pe acest plan s-a reprezentat numai distribuitorul, colectorul se va realiza la in  
aceleasi conditiii



Nr. Ctl.	DENUMIRE	Nr. Buc.	TIP	DIMENSIUNE	OBSERVATII
11	Flansa plata	1	OL 37-2K	Dn 65, Pn 10	STAS 8013 - 84
10	Stur circuit incalzire bloc 2; teava OL	1	OLT 35	88,9 x 4,0 x 100	STAS 403
9	Ansamblu suport sustinere	3		-	Plansa T.De - 01
8	Stur filetat; teava OL	1	OLT 35	26,4 x 2,3 x 50	STAS 403
7	Stur filetat; teava OL	1	OLT 35	21,3 x 2,3 x 50	STAS 403
6	Flansa plata	2	OL 37-2K	Dn 80, Pn 10	STAS 8013 - 84
5	Stur circuit cazane; teava OL	1	OLT 35	139,7 x 4,85 x 90 mm	STAS 403
4	Stur circuit incalzire bloc 3; teava OL	1	OLT 35	88,9 x 4,0 x 100	STAS 403
3	Stur boilerie 2+3; teava OL	1	OLT 35	76,6 x 3,65 x 90	STAS 403
2	Stur boilerie 1; teava OL	1	OLT 35	42,49 x 3,2 x 100	STAS 403
1	Corp distribuitor	1	OLT 35	273,1 x 5,2 x 3200 mm	SR 11082